

watercycle™ - 3" x 29"			Fresh Water		Drain Water	
LOG PERIOD	TIME	DATE	Cold In	Pre-heated	Shower In	Drain
1	11:04:11 AM	4/6/2006	6.1	18	37.1	29.8
2	11:04:12 AM	4/6/2006	6.1	18	37.1	29.8
3	11:04:13 AM	4/6/2006	6.1	18	37.1	29.7
4	11:04:14 AM	4/6/2006	6.5	18	37.1	29.7
5	11:04:15 AM	4/6/2006	6.5	18	37.1	29.7
6	11:04:16 AM	4/6/2006	6.5	18	37.1	29.8
7	11:04:17 AM	4/6/2006	6.2	18	37.1	29.8
8	11:04:18 AM	4/6/2006	6.2	17.9	37.1	29.8
9	11:04:19 AM	4/6/2006	6.2	17.9	37.1	29.8
10	11:04:20 AM	4/6/2006	6.2	17.9	37.1	29.8
11	11:04:21 AM	4/6/2006	6.1	18	37.1	29.8
12	11:04:22 AM	4/6/2006	6.1	18	37.2	29.8
13	11:04:23 AM	4/6/2006	6.1	18	37.2	29.7
14	11:04:24 AM	4/6/2006	6.2	18	37.2	29.7
15	11:04:25 AM	4/6/2006	6.2	18	37.2	29.7
16	11:04:26 AM	4/6/2006	6.2	18	37.1	29.7
17	11:04:27 AM	4/6/2006	6.3	18	37.1	29.6
18	11:04:28 AM	4/6/2006	6.3	17.9	37.1	29.6
19	11:04:29 AM	4/6/2006	6.3	17.9	37	29.6
20	11:04:30 AM	4/6/2006	6.3	17.9	37	29.6
21	11:04:31 AM	4/6/2006	6.2	17.9	37	29.6
22	11:04:32 AM	4/6/2006	6.2	18	37	29.6
23	11:04:33 AM	4/6/2006	6.2	18	37	29.6
24	11:04:34 AM	4/6/2006	6.3	18	37	29.6
25	11:04:35 AM	4/6/2006	6.3	17.9	37	29.6
26	11:04:36 AM	4/6/2006	6.3	17.9	37	29.6
27	11:04:37 AM	4/6/2006	6.3	17.9	37	29.6
28	11:04:38 AM	4/6/2006	6.4	17.9	37	29.6
29	11:04:39 AM	4/6/2006	6.4	18.1	36.9	29.6
30	11:04:40 AM	4/6/2006	6.4	18.1	36.9	29.6
31	11:04:41 AM	4/6/2006	6.5	18.1	36.9	29.6
32	11:04:42 AM	4/6/2006	6.5	18	36.9	29.6
33	11:04:43 AM	4/6/2006	6.5	18	37.1	29.6
34	11:04:44 AM	4/6/2006	6.5	18	37.1	29.6
35	11:04:45 AM	4/6/2006	6.5	18	37.1	29.6
36	11:04:46 AM	4/6/2006	6.5	18	37.1	29.6
37	11:04:47 AM	4/6/2006	6.5	18	37.1	29.6
38	11:04:48 AM	4/6/2006	6.3	18	37.1	29.6
39	11:04:49 AM	4/6/2006	6.3	18	37.1	29.6
40	11:04:50 AM	4/6/2006	6.3	18	37.1	29.6
41	11:04:51 AM	4/6/2006	6.3	18	37.1	29.6
42	11:04:52 AM	4/6/2006	6.2	17.9	37.1	29.6
43	11:04:53 AM	4/6/2006	6.2	17.9	37	29.6
44	11:04:54 AM	4/6/2006	6.2	17.9	37	29.6
45	11:04:55 AM	4/6/2006	6.4	17.9	37	29.6
46	11:04:56 AM	4/6/2006	6.4	17.8	37	29.6
47	11:04:57 AM	4/6/2006	6.4	17.8	37	29.6
48	11:04:58 AM	4/6/2006	6.3	17.8	37	29.6

49	11:04:59 AM	4/6/2006	6.3	18	37	29.6
50	11:05:00 AM	4/6/2006	6.3	18	36.9	29.6
51	11:05:01 AM	4/6/2006	6.3	18	36.9	29.6
52	11:05:02 AM	4/6/2006	6.3	18	36.9	29.6
53	11:05:03 AM	4/6/2006	6.3	18	36.9	29.6
54	11:05:04 AM	4/6/2006	6.3	18	37	29.5
55	11:05:05 AM	4/6/2006	6.2	18	37	29.5
56	11:05:06 AM	4/6/2006	6.2	18	37	29.5
57	11:05:07 AM	4/6/2006	6.2	18	37.3	29.5
58	11:05:08 AM	4/6/2006	6.2	18	37.3	29.5
59	11:05:09 AM	4/6/2006	6.3	18	37.3	29.5
60	11:05:10 AM	4/6/2006	6.3	18	37.1	29.5
61	11:05:11 AM	4/6/2006	6.3	18	37.1	29.6
62	11:05:12 AM	4/6/2006	6.4	18	37.1	29.6
63	11:05:13 AM	4/6/2006	6.4	18	37.1	29.6
64	11:05:14 AM	4/6/2006	6.4	18	37	29.6
65	11:05:15 AM	4/6/2006	6.4	18	37	29.6
66	11:05:16 AM	4/6/2006	6.2	18	37	29.6
67	11:05:17 AM	4/6/2006	6.2	17.9	37.1	29.6
68	11:05:18 AM	4/6/2006	6.2	17.9	37.1	29.6
69	11:05:19 AM	4/6/2006	6.2	17.9	37.1	29.6
70	11:05:20 AM	4/6/2006	6.2	18	37.1	29.6
71	11:05:21 AM	4/6/2006	6.2	18	37	29.6
72	11:05:22 AM	4/6/2006	6.2	18	37	29.5
73	11:05:23 AM	4/6/2006	6.2	18	37	29.5
74	11:05:24 AM	4/6/2006	6.2	18	36.8	29.5
75	11:05:25 AM	4/6/2006	6.2	18	36.8	29.6
76	11:05:26 AM	4/6/2006	6.3	18	36.8	29.6
77	11:05:27 AM	4/6/2006	6.3	18	36.8	29.6
78	11:05:28 AM	4/6/2006	6.3	18	37	29.6
79	11:05:29 AM	4/6/2006	6.3	18	37	29.6
80	11:05:30 AM	4/6/2006	6.3	18	37	29.6
81	11:05:31 AM	4/6/2006	6.3	18	36.8	29.6
82	11:05:32 AM	4/6/2006	6.3	18	36.8	29.5

**Averages** 6.289024 17.97439 37.03537 29.61707

**Cold water temp increase** 11.685366

**Effectiveness** 38.01%